

# DECLARATION OF PERFORMANCE

According to Annex III of the Regulation (EU) Nr.305/2011 (Construction Products Regulation)

fischer FPC® Panel Coating

Coating

EN

## 1121 – CPR – JA5048



1. Unique identification code of product-type:

FPC (Panel Coating)

2. Type, Batch or serial number as required pursuant to Article 11(4):

See ETA 14/0382: See batch number displayed on product.

3. Intended use or uses of construction product, in accordance with the applicable harmonized technical specification:

Fire Stopping and Sealing Products for Penetration Seals, See ETA 14/0382

Cable Penetration	Insulated & non insulated, cables, cable trays & cable ladders	The field of application has to comply with the content of ETA 14/0382
Pipe Penetration	Insulated & non insulated metal pipes	The field of application has to comply with the content of ETA 14/0382

4. Name, registered trade name or registered trade mark and contact address as required pursuant to article 11(5):

fischerwerke GmbH & Co. KG, Klaus-Fischer-Str. 1, 72178 Waldachtal, DEUTSCHLAND

5. Authorized representative: N/A

6. System or systems of assessment and verification of performance of the construction product as set out in Annex V: AVCP - System 1

7. Harmonized standard: N/A

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Warrington Certification Limited issued European Technical Approval - ETA 14/0382 on the basis of ETAG 026 part 1 General June 2013 fire protection products & ETAG 026 part 2 August 2011 fire stopping and fire sealing products & issued certificate of conformity 1121-CPR-JA5048

9. Declared performance:

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class F According to EN13501-1
Resistance to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See ETA 14/0382 clause 3.2 - Annex C
Air Permeability	Tested in accordance with EN 1026, See ETA 14/0382 Clause 3.3 - 600Pa
Dangerous Substance	See ETA 14/0382 Clause 3.5
Airborne Sound Insulation	Tested in accordance with EN ISO 10140-2:2010 & EN ISO 140-3 & EN ISO 717-1 See ETA 14/0382 - Rw (C;Ctr) = 34 (G;-2)db
Service & Durability	Z <sup>1</sup> (0/+40°C) intended for use at internal conditions with high humidity (85%) in accordance with EOTA technical documents TR024
Movement Capabilities	According to ISO 11600: ISO 11600 - F - 12.5p.
Other	Not applicable/No performance determined

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

**Dave Hanrahan**

Product Manager FireStop ST-F

**Gürol Sevim**

Head of SaMontec – Installation Systems ST-S

Telefon +49 7443 12-0  
Fax +49 7443 12-4222  
Internet www.fischer.de  
GLN 40 06209 00000 7  
UST-IdNr. DE 144252337

Sitz: Weinalde 14 – 18, 72178 Waldachtal, Deutschland  
Registergericht Stuttgart HRA 440255  
Komplementär:  
fischerinternational Beteiligungs GmbH  
Wiener Straße 95, 2514 Traiskirchen, Österreich  
Landesgericht Wiener Neustadt FN 319271 t

Geschäftsführer:  
Professor E. h. Senator E. h. E. h.  
Dipl.-Ing. (FH) Klaus Fischer  
Jürgen Wässner  
Marc-Sven Mengis  
Boris Katic  
Dr. Christian P. Heine

Bankverbindung:  
Baden-Württembergische Bank  
BLZ 600 501 01, Kto. 4 903 000  
IBAN DE98 6005 0101 0004 9030 00  
SWIFT SOLADEST600

