

DECLARATION OF PERFORMANCE

According to Annex III of the Regulation (EU) Nr.305/2011 (Construction Products Regulation)

fischer FCPS® Coated Panel System

Fire Batt

EN

1121 – CPR – JA5050



1. Unique identification code of product-type:
FCPS (Coated Panel System)

2. Type, Batch or serial number as required pursuant to Article 11(4):
See ETA 14/0388: See batch number displayed on product.

3. Intended use or uses of construction product, in accordance with the applicable harmonized technical specification:
Fire Stopping and Sealing Products for Penetration Seals, See ETA 14/0388

Cable Penetration	Insulated & non insulated, cables, cable trays & cable ladders	The field of application has to comply with the content of ETA 14/0388
Pipe Penetration	Insulated & non insulated metal pipes	The field of application has to comply with the content of ETA 14/0388

4. Name, registered trade name or registered trade mark and contact address as required pursuant to article 11(5):
fischerwerke GmbH & Co. KG, Klaus-Fischer-Str. 1, 72178 Waldachtal, DEUTSCHLAND

5. Authorized representative: N/A

6. System or systems of assessment and verification of performance of the construction product as set out in Annex V: AVCP - System 1

7. Harmonized standard: N/A

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:
Warrington Certification Limited issued European Technical Approval - ETA 14/0388 on the basis of ETAG 026 part 1 General fire protection products & ETAG 026 part 2 August 2011 fire stopping and fire sealing products & issued certificate of conformity 1121-CPR-JA5050

9. Declared performance:


Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class F According to EN13501-1
Resistance to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See ETA 14/0388 clause 3.2 - Annex C
Air Permeability	Tested in accordance with EN 1026, See ETA 14/0388 Clause 3.3
Dangerous Substance	See ETA 14/0388 Clause 3.5
Airborne Sound Insulation	Tested in accordance with EN ISO 10140-2:2010 & EN ISO 140-3 & EN ISO 717-1 See ETA 14/0388 - Rw (C;Ctr) = 27 (Dnew) = 37db
Service & Durability	Z ¹ (0/+40°C) intended for use at internal conditions with high humidity (85%) in accordance with EOTA technical documents TR024
Other	Not applicable/No performance determined

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



Dave Hanrahan
Product Manager FireStop ST-F



Gürol Sevim
Head of SaMontec – Installation Systems ST-S