

DECLARATION OF PERFORMANCE

According to Annex III of the Regulation (EU) Nr.305/2011 (Construction Products Regulation)

fischer FiP® Intumescent Pillow

Pillow

EN

1121 – CPR – JA5046



1. Unique identification code of product-type:

FiP (Intumescent Pillow)

2. Type, Batch or serial number as required pursuant to Article 11(4):

See ETA 14/0380: See batch number displayed on product.

3. Intended use or uses of construction product, in accordance with the applicable harmonized technical specification:

Fire Stopping and Sealing Products for Penetration Seals, See ETA 14/0380

Cable Penetration	Insulated & non insulated, cables, cable trays & cable ladders	The field of application has to comply with the content of ETA 14/0380
Pipe Penetration	Insulated & non insulated metal pipes	The field of application has to comply with the content of ETA 14/0380

4. Name, registered trade name or registered trade mark and contact address as required pursuant to article 11(5):

fischerwerke GmbH & Co. KG, Klaus-Fischer-Str. 1, 72178 Waldachtal, DEUTSCHLAND

5. Authorized representative: N/A

6. System or systems of assessment and verification of performance of the construction product as set out in Annex V: AVCP - System 1

7. Harmonized standard: N/A

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Warrington Certification Limited issued European Technical Approval - ETA 14/0380 on the basis of ETAG 026 part 1 General June 2013 fire protection products & ETAG 026 part 2 August 2011 fire stopping and fire sealing products & issued certificate of conformity 1121-CPR-JA5046

9. Declared performance:

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class F According to EN13501-1
Resistance to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See ETA 14/0380 clause 3.2 - Annex C
Air Permeability	Tested in accordance with EN 1026, See ETA 14/0380 Clause 3.3
Dangerous Substance	See ETA 14/0380 Clause 3.5
Airborne Sound Insulation	Tested in accordance with EN ISO 10140-2:2010 & EN ISO 717-1 See ETA 14/0382 - Rw (C;Ctr) = 33 (G;-2)db
Service & Durability	Z ¹ (0/+40°C) intended for use at internal conditions with high humidity (85%) in accordance with EOTA technical documents TR024
Other	Not applicable/No performance determined

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Dave Hanrahan

Product Manager FireStop ST-F

Gürol Sevim

Head of SaMontec – Installation Systems ST-S

Telefon +49 7443 12-0
Fax +49 7443 12-4222
Internet www.fischer.de
GLN 40 06209 00000 7
UST-IdNr. DE 144252337

Sitz: Weinhalde 14 – 18, 72178 Waldachtal, Deutschland
Registergericht Stuttgart HRA 440255
Komplementär: fischerinternational Beteiligungs GmbH
Wiener Straße 95, 2514 Traiskirchen, Österreich
Landesgericht Wiener Neustadt FN 319271 t

Geschäftsführer: Professor E. h. Senator E. h. E. h.
Dipl.-Ing. (FH) Klaus Fischer
Jürgen Wässner
Marc-Sven Mengis
Boris Katic
Dr. Christian P. Heine

Bankverbindung: Baden-Württembergische Bank
BLZ 600 501 01, Kto. 4 903 000
IBAN DE98 6005 0101 0004 9030 00
SWIFT SOLADEST600

